





State Water Resources Control Board

September 28, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5949

Mr. Joel Coria Hazmat Coordinator Caltrans 3940 Rosin Court Sacramento, California 95834 joel.coria@dot.ca.gov

SUBJECT:

NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS LOCATED AT CALTRANS - SPECIAL CREWS, 1403 FURNEAUX ROAD.

OLIVEHURST

Dear Mr. Coria:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on September 26, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

| No. | Violation | Tank | Start Date | Stop Date | Regulation |
|-----|--|------|-----------------------|-----------|--|
| 1 | Failure to Maintain Tank Information – In CERS, the tank information forms incorrectly listed the overfill method as a fill tube shut off device; however, none were observed at the time of inspection. Confirm the correct overfill method and update the tank information form. | All | September 26, 2018 | Ongoing | 23 CCR 2711(a) |
| 2 | Failure to Maintain Monitoring Plan – The monitoring plan sensor model numbers and responsible persons must be updated. | All | September 26, 2018 | Ongoing | H&SC 25286(a); 23 CCR 2632(d)(1), 2711(a)(9) |

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

| No. | Violation | Tank | Start Date | Stop Date | Regulation |
|-----|---|------|-----------------------|-----------|-------------------------------------|
| 4 | Failure to Maintain Plot Plan/Site Map – An approved plot plan/site map indicating the location of the product piping, tanks, and auxiliary equipment, with respect to buildings or other landmarks, was not available in CERS or onsite at the time of the inspection. | All | September 26, 2018 | Ongoing | 23 CCR 2711(a)(8) |
| 5 | Failure to Provide Designated Operator (DO) Training – A current list of employees trained by the DO was not available at the time of inspection. Employees must receive annual training by the DO. | All | September 26, 2018 | Ongoing | 23 CCR 2715(f) |
| 6 | Failure to Maintain Monitoring or Testing Records Onsite – There were not 3 years of monitoring or testing records onsite at the time of inspection. | All | September 26, 2018 | Ongoing | H&SC 25293; 23 CCR 2712(b) |
| 7 | Failure to Tag Monitoring Equipment – The monitoring certification tags were not attached to any of the sensors and line leak detectors at the time of inspection. | All | September 26, 2018 | Ongoing | 23 CCR 2638(f) |

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Yuba County Environmental Health Department within sixty (60) days from the date of this letter. Have your DO make specific notations in the next monthly DO report indicating the ongoing violations have been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Ms. Rebecca Green
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
rebecca.green@waterboards.ca.gov

Local CUPA

Mr. Clark Allen Pickell
Director Environmental Health
Yuba County Environmental
Health Department
915 8th Street, Suite 123
Marysville, California 95901
cpickell@co.yuba.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel

Senior Environmental Scientist

UST Enforcement Unit

Office of Enforcement

CC:

(via email only)

Mr. Gary Cantwell
Program Supervisor
Yuba County Environmental
Health Department
gcantwell@co.yuba.ca.us

Mr. Clark Allen Pickell, Director Environmental Health Yuba County Environmental Health Department cpickell@co.yuba.ca.us